



Sensepoint XCD SPECIFICATIONS

Flammable, toxic and oxygen gas detector for industrial applications

Use	3 wire, 4-20mA and RS485 MODBUS output fixed point detector with in-built alarm and fault relays for the protection of personnel and plant from flammable, toxic and Oxygen hazards. Incorporates a transmitter with local display and fully configurable via non-intrusive magnetic switch interface.										
Electrical											
Input Voltage Range	12 to 32VDC (24VDC nominal)										
Max Power Consumption	Maximum power consumption is dependent on the type of gas sensor being used. Electrochemical cells = 3.7W, IR = 3.7W and catalytic = 4.9W. Maximum inrush current = 800mA at 24VDC										
Current Output Relays	Sink or source 3 x 5A@250VAC. Selectable normally open or normally closed (switch) and energized/de-energised (programmable) Alarm relays default normally open/de-energized. Fault relay default normally open/energized										
Communication	RS485, MODBUS RTU										
Construction											
Material	Housing: Epoxy painted aluminium alloy ADC12 or 316 stainless steel Sensor: 316 stainless steel										
Weight (approx)	Aluminium Alloy LM25: 4.4lbs 316 Stainless Steel: 11 lbs										
Mounting	Integral mounting plate with 4 x mounting holes suitable for M8 bolts. Optional pipe mounting kit for horizontal or vertical pipe Ø1.5 to 3" (2" nominal)										
Cable Entries	UL\cUL versions: 2 x ¾"NPT conduit entries. Suitable blanking plug supplied for use if only 1 entry used. Seal to maintain IP rating; ATEX/IECEx versions: 2 x M20 cable entries										
Environmental											
IP Rating	IP66 in accordance with EN60529:1992										
Certified Temperature Range	-40°F to +149°F (-40°C to +65°C)										
Detectable Gases and XCD Sensor Performance											
Gas	User Selectable Full Scale Range	Default Range	Steps	User Selectable Cal Gas Range	Default Cal Point	Response Time (T90) Secs	Accuracy	Operating Temperature		Default Alarm Points	
								Min	Max	A1	A2
Electrochemical Sensors											
Oxygen	25.0%Vol. only	25.0%Vol.	n/a	20.9%Vol. (Fixed)	20.9%Vol.	<30	<±0.5%Vol.	-20°C / -4°F	55°C / 131°F	19.5%Vol. ▼	23.5%Vol. ▲
Hydrogen Sulfide*	10.0 to 100.0ppm	50.0ppm	0.1ppm		25ppm	<50	<±1ppm	-20°C / -4°F	55°C / 131°F	10ppm ▲	20ppm ▲
Carbon Monoxide**	100 to 1,000ppm	300ppm	100ppm		100ppm	<30	<±6ppm	-20°C / -4°F	55°C / 131°F	30ppm ▲	100ppm ▲
Hydrogen	1,000ppm only	1,000ppm	n/a		500ppm	<65	<±25ppm	-20°C / -4°F	55°C / 131°F	200ppm ▲	400ppm ▲
Nitrogen Dioxide***	10.0 to 50.0ppm	10.0ppm	5.0ppm		5.0ppm	<40	<±3ppm	-20°C / -4°F	55°C / 131°F	5.0ppm ▲	10.0ppm ▲
* Lowest Alarm Limit = 1ppm; Lowest Detection Limit = .5ppm ** Lowest Alarm Limit = 15 ppm; Lowest Detection Limit = 10ppm *** Lowest Alarm Limit = 0.6 ppm; Lowest Detection Limit = 0.3ppm					30 to 70% of selected full scale range						
Catalytic Bead Sensors											
Flammable 1 to 8	20.0 to 100.0%LEL	100%LEL	10%LEL		50%LEL	<25	<±1.5%LEL	-20°C / -4°F	55°C / 131°F	20%LEL ▲	40%LEL ▲
Infrared Sensors											
Methane	20.0 to 100.0%LEL	100%LEL	10%LEL		50%LEL	<30	<±1.5%LEL	-20°C / -4°F	50°C / 122°F	20%LEL ▲	40%LEL ▲
Propane	20 to 100%LEL	100%LEL	10%LEL		50%LEL	<30	<±1%LEL	-20°C / -4°F	50°C / 122°F	20%LEL ▲	40%LEL ▲
Carbon Dioxide	2%Vol. only	2%Vol.	n/a		1%Vol.	<30	<±0.04%Vol.	-20°C / -4°F	50°C / 122°F	0.4%Vol. ▲	0.8%Vol. ▲
NOTE: For Cat Bead and Infrared sensors, Lowest Detectable Limit is 5% LEL and Lowest Alarm Level is 10% LEL. ▲ - Rising Alarm ▼ - Falling Alarm											
Certification											
US, Latin America, Canada	UL/c-UL - Class I, Division 1, Groups B, C and D, Class I, Division 2, Groups B, C & D, Class II, Division 1, Groups E, F & G, Class II, Division 2, Groups F & G. -40°C to +65°C										
European International	ATEX Ex II 2 GD Ex d IIC Gb T6 (Ta -40°C to +65°C) Ex tb IIIC T85°C Db IP66 IEC Ex d IIC Gb T6 (Ta -40°C to +65°C) Ex tb IIIC T85°C Db IP66										
EMC	CE: EN50270:2006 EN6100-6-4:2007										
Performance	UL508; CSA 22.2 No. 152 (flammable gasses, excludes infrared sensors); ATEX, IEC/EN60079-29-1:2007, EN45544, EN50104, EN50271; China: PA Pattern Measurement (for transmitter and toxic gas sensors) "CCCC" Shenyang for Flammable (fire dept approval)										